

Test Report

Requirements of general application resulting from Commission Regulation (EU) 2016/631 of 14 April 2016 establishing a network code on requirements for grid connection of generators (NC RfG)

For the unit(s) GIV-3HY-6.0-HV, GIV-3HY-8.0-HV, GIV-3HY-10.0-HV, GIV-3HY-11.0-HV

Test report no 230407146GZU-001

Date 2023-July-08



www.intertek.com

intertek Total Quality. Assured.

Test report number:	230407146GZU-001
Date of issue	2023-07-08
Total number of pages:	9 pages
Testing laboratory:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Address	Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room
	01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China
Applicant's name:	Shenzhen Givenergy Co., Ltd
Address	6 # -1001, 1002, 1003, 1004, Building 6, Chuangwei Innovation
	Valley, No 8Tangtou 1st Road, Shiyan Sub-district, Bao'an District, Shenzhen, China.
Factory:	Shenzhen GivEnergy Co., Ltd
Address 1	201, No 38, Xingda Road, Yanchuan Community, Yanluo Sub- district, Bao'an District, Shenzhen, Guangdong Province, China.
Address 2	1st Floor, 2nd Floor, 3rd Floor, No 21, Liaokeng1st Industrial Park, Baoyuan Community, Shiyan Sub-district, Bao'an District, Shenzhen, Guangdong Province, China.
Test specification	
Standard:	PTPiREE 2021
	PSE:18 December 2018 (NC RfG)
	COMMISSION REGULATION (EU) 2016/631 (NC RfG)
	Type approval for Type A PPMs
Test report form number	NC RfG_V1.0
Test report form(s) originator	Intertek
Master TRF	Dated 2023-01-24
Test item description	PV Hybrid inverter
Trademark	GivEnergy
Manufacturer	Same as applicant
Model / Type reference:	GIV-3HY-6.0-HV, GIV-3HY-8.0-HV, GIV-3HY-10.0-HV, GIV-3HY-11.0-HV
Technical data	See section 3.1.1 on p.5
Testing location / address:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China
Dates of testing	24 May 2023 – 08 July 2023

This test report shall not be reproduced except in full without approval of Intertek Testing Services Shenzhen Ltd. Guangzhou Branch. Test reports without signature are not valid.

Tested by

Drewe Zhou Engineer

Approved by

Jason Tu

Jason Fu Supervisor



1 General information of test report

1.1 Revision history

Revision	Date	Editor	Modification / Change	Status
1	2023-07-08	Drewe Zhou	Initial report was written	active



2 General remarks for documentation

The test results presented in this report relate only to the object(**s**) tested.

Throughout this report a \boxtimes comma ',' / \square point '.' is used as decimal separator and a \square point '.' / \square comma ',' as thousands separator.

Remark:

This report should be used together with report no. 230407144GZU-001, 08 July 2023.



General remarks for testing

3.1 General product information


3.1.1 Technical data of the unit(s)

Model	GIV-3HY-6.0- HV	GIV-3HY-8.0- HV	GIV-3HY-10.0- HV	GIV-3HY-11.0- HV
Input Date (PV)	•			
Max. PV array open-circuit Voltage	1000Vd.c			
Max. total PV array short-circuit circuit	2*20Ad.c			
Max. operating PV input current	2*15Ad.c			
PV input operating voltage range	200~1000Vd.c			
MPPT input operating voltage range	200~850Vd.c			
Number of independent MPP input		2		
Output Date (AC)				
Nominal AC output Power	6000W	8000W	10000W	11000W
AC nominal voltage		230/400Va.c		
AC grid frequency		50)Hz	
Nominal output current (pure phase)	8.7Aa.c	11.6Aa.c	14.5Aa.c	15.9Aa.c
Max. output current (pure phase)	10.5Aa.c	13.5 Aa.c	16.5 Aa.c	18 Aa.c
Power factor (Full load)		>0.99		
Backup terminal parameter (AC)				
Nominal AC output Power	6000W	8000W	10000W	11000W
AC nominal voltage	230/400Va.c			
AC grid frequency		50)Hz	
Nominal output current (pure phase)	8.7Aa.c	11.6Aa.c	14.5Aa.c	15.9Aa.c
Max. output current (pure phase)	10.5Aa.c	13.5 Aa.c	16.5 Aa.c	18 Aa.c
Battery				
Battery Type		Li	-ion	
Normal voltage		4	50V	
Operating voltage range	200~600V			
Max. charging current	25Ad.c			
Max. discharging current	25Ad.c			
Max. charging Power	6000W	8000W	10000W	11000W
Max. discharging Power	6000W	8000W	10000W	11000W
Others				
Ingress protection		IF	P65	
Protective Class	Class I			
Operating Temperature Range	-25℃~60℃			

Equipment mobility	pluggable equipment
Operating condition:	Continuous
Class of equipment:	Class I
Protection against ingress of water:	IP65 according to EN 60529

The unit is bidirectional which applies to the PV system with battery storage. Energy produced by the PV system is used to optimize self-consumption. Excess energy is used to charge the batteries, and then fed into the public grid when the PV energy is adequate.

When PV energy output is insufficient to support connected loads, the system automatically draws energy from the batteries if battery capacity is sufficient. If the battery capacity is insufficient to meet own consumption requirements, electricity will be drawn from the public grid.



The topology diagram as following:

3.1.2 Description of the differences of the models within the product series

All models have identical mechanical and electrical construction except some parameter of the software architecture to control the max output power.

The Software version: ZA1.0

The Hardware version: V1.0



3.1.3 Copy of marking plate

000Vd.c. 2 X 20Ad.c. 2 X 15Ad.c. 200 ~ 1000Vd.c. 200 ~ 850Vd.c.	Input Data(PV) Max. PV Array Open-circuit Voltage Max. Total PV Array Short-circuit Current Max. PV Input Operating Current PV Input Operating Voltage Range	1000Vd.c. 2 X 20Ad.c. 2 X 15Ad.c. 200 ~ 1000Vd		
2 X 20Ad.c. 2 X 15Ad.c. 200 ~ 1000Vd.c. 200 ~ 850Vd.c.	Max, Total PV Array Short-circuit Current Max, PV Input Operating Current PV Input Operating Voltage Range	2 X 20Ad.c. 2 X 15Ad.c.		
2 X 15Ad.c. 200 ~ 1000Vd.c. 200 ~ 850Vd.c.	Max. PV Input Operating Current PV Input Operating Voltage Range			
200 ~ 1000Vd.c. 200 ~ 850Vd.c.	PV Input Operating Voltage Range			
200 ~ 850Vd.c.		200 ~ 1000Vd		
	MPPT Input Operating Voltage Range	200 ~ 850Vd.d		
	Number Of Independent MPP Input	2		
	Output Data(AC)			
000W	Nominal AC Output Power	8000W		
00/230Va.c.	Nominal AC Voltage	400/230Va.c.		
i0Hz	AC Grid Frequency	50Hz		
0.5Aa.c.	Max. Output Current	13.5Aa.c.		
0.99	Power Factor(Full Load)	>0.99		
Backup Terminal Paremeter(AC)		Backup Terminal Paremeter(AC)		
W000	Nominal AC Output Power	8000W		
00/230Va.c.	Nominal AC Voltage	400/230Va.c.		
i0Hz	AC Grid Frequency	50Hz		
0.5Aa.c.	Max. Output Current	13.5Aa.c.		
	Battery			
.i-ion	Battery Type	Li-ion		
50V	Nominal Voltage	450V		
200~600V	Operating Voltage Range	200~600V		
5Ad.c.	Max.Charging Current	25Ad.c.		
5Ad.c.	Max.Discharging Current	25Ad.c.		
000W	Max.Charging Power	8000W		
000W	Max. Discharging Power	8000W		
	Others			
P65	Ingress Protection	IP65		
Class I	Protective Class	Class I		
	00/230Va.c. 0Hz 0.5Aa.c. 0.99 000W 00/230Va.c. 0Hz 0.5Aa.c. 0Hz 0.5Aa.c. 50V 00~600V 5Ad.c. 5Ad.c. 000W 000W	00/230Va.c. Nominal AC Voltage 0Hz AC Grid Frequency 0.5Aa.c. Max. Output Current 0.99 Power FactoryFull Load) Backup Terminal Paremeter(AC) 000/230Va.c. Nominal AC Voltage 001/230Va.c. Max. Output Current Battery Battery I-ion Battery Type S0V Nominal Voltage Range 000-600V Operating Voltage Range SAd.c. Max.Charging Current SAd.c. Max.Discharging Power 0000W Max. Discharging Power 0000W Others 265 Ingress Protection		



GIV-3HY-11.0-HV Voltage 1000Vd.c. rouit Current 2 X 20Ad.c. arrent 2 X 15Ad.c. Range 200 ~ 1000Vd.c. rge Range 200 ~ 850Vd.c. P Input 2 11000W 400/230Va.c. 50Hz		
rouit Current 2 X 20Ad.c. urrent 2 X 15Ad.c. Range 200 ~ 1000Vd.c. rge Range 200 ~ 850Vd.c. P Input 2 11000W 400/230Va.c. 50Hz		
ament 2 X 15Ad.c. Range 200 ~ 1000Vd.c. rge Range 200 ~ 850Vd.c. PP Input 2 11000W 400/230Va.c. 50Hz 50Hz		
Range 200 ~ 1000Vd.c. age Range 200 ~ 850Vd.c. PP Input 2 11000W 400/230Va.c. 50Hz 50Hz		
ege Range 200 ~ 850Vd.c. PP Input 2 11000W 400/230Va.c. 50Hz		
2 11000W 400/230Va.c. 50Hz		
11000W 400/230Va.c. 50Hz		
400/230Va.c. 50Hz		
400/230Va.c. 50Hz		
50Hz		
101		
18Aa.c.		
>0.99		
Backup Terminal Paremeter(AC)		
11000W		
400/230Va.c.		
50Hz		
18Aa.c.		
· · · · · · · · · · · · · · · · · · ·		
Li-ion		
450V		
200~600V		
25Ad.c.		
25Ad.c.		
11000W		
11000W		
IP65		
Class I		
-25~+60 °C		
n		

Note:

- 1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
- 2. Label is attached on the side surface of enclosure and visible after installation.



3.2 Scope of measurements

3.2.1 General

The assessment covers requirements applicable to Types A Power Park Modules (PPMs) for which Equipment Certificates are requested in the Polish certification guideline, as further detailed in Section 3.2.2. The assessment covers both exhaustive requirements, fully defined by the NC RfG, and non-exhaustive requirements, for which complementary requirement details have been collected from the national specification for Poland in PSE 2018-12. ss

The scope of assessment covers the following:

- The completeness of documents and measurements
- The plausibility of the documents received
- The compliance of the test conditions of the documents with those listed in standard

• The assessment of the measurement results concerning the requirements of the documents listed in standard

3.2.2 Paragraphs of NC RfG within scope

Capability	NC RfG	PSE 2018-12	Туре А	Assessment result
Frequency range	13.1(a)	13.1(a)(i)	x	Compliant
Rate of Change of Frequency (ROCOF) Withstand capability, df/dt	13.1(b)	13.1(b)	x	Compliant
Remote cessation of active power	13.6	13.6	x	Compliant
Limited Frequency Sensitive Mode – Over frequency (LFSM-O)	13.2	13.2(a).(b).(f)	x	Compliant

Capability	NC RfG	PSE 2018-12	Based on EN 50549-1 test report, report no. 230523124GZU-001
Frequency range	13.1(a)	13.1(a)(i)	Refer to item 4.4.2
Rate of Change of Frequency (ROCOF) Withstand capability, df/dt	13.1(b)	13.1(b)	Refer to item 4.5.2
Remote cessation of active power	13.6	13.6	Refer to item 4.11
Limited Frequency Sensitive Mode – Over frequency (LFSM-O)	13.2	13.2(a).(b).(f)	Refer to item 4.6.1

End of Test Report