

Certificate

Applicant: **SolarEdge Technologies**
1 HaMada Street
Herzeliya 4673335
Israel

Product: **Photovoltaic Inverter**

Model: **SE25K, SE27.6K, SE33.3K**

Intended use:

Automatic disconnection device with three-phase mains surveillance in accordance with VDE 0126-1-1 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

The **SE33.3K is suitable** to be used only with an external 277/230V transformer in order to fulfill the requirements of the standard.

Applied standards and guidelines:

DIN VDE 0126-1-1 (VDE V 0126-1-1):2013-08

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 15PP010-19

Certificate No: 16-117-00

Date of issue: 2016-08-31



A handwritten signature in black ink, appearing to read 'A. Aufmuth', is written over a light blue circular background.

Andreas Aufmuth
Certification Body

