


Please read carefully before installation.

PROJOY electric - Switch To Safety! -

PEDSC100R/120R-EL

ENCLOSURE DC ISOLATOR Instructions for Installation and Operation



- Be sure number(1,3,5,7) on switch and "IP66NW" on cover are not inverted.
- Rotate Handel to the "OFF" position and locate shaft into switch body.
- Tighten screw 1,3,2,4 IN THAT ORDER.
- Make sure that number(5) is assembled on cover.

Instructions for Installation and Operation

The switch with a box is suitable for outdoor use. Ithe solar at 40 °C = 32A, Ithe solar at 60°C=29A


Please note that all connections (including bridging link connections) should be tightening before energization.


DC Switch Disconnector for Photovoltaics Wiring diagram


	4	В	
1	3	5	7
个	7-	7_	$\overline{}$
j	j	j	j
2	4	6	8
	4	IS	
1	3	5	7
T	٦,	7	Ų.
))	Ţ	١
2	4	6	8


4P				
1	3	5	7	
4	√'-	꺆	\	
2	4	6	1 8	
_	7	•	U	
		_		
	4	·T		
1	4 3	T 5	7	
1	_		7	
1 - 1	_		7	


Switching examples











Cable cross sections

Rigid(Stranded or solid)



Flexible

Screwdriver,	Tightening	torque
Colcwallvel,	rigincining	torque



MA



1.2-1.8Nm

Mounting Type

Enclosure(IP66NW)

Vertically or Horizontally

Switch body(IP20)

Vertically <u>↑</u>↑



XinTang Industrial Zone, PingJiang District, Suzhou, China

Tel: +86 512 6878 6489 Fax: +86 512 6878 6489 Web: www.projoy-electric.com E-mail: sales@projoy-electric.com