

## DECLARATION OF EN50438 for Netherland

Manufacturer	Name	NINGBO GINLONG TECHNOLOGIES CO., LTD.
	Address	NO. 57 JINTONG ROAD, BINHAI INDUSTRIAL PARK, XIANGSHAN, NINGBO, ZHEJIANG, 315712, CHINA
Product	Product Name	GRID-TIE PV INVERTER
	Model	THREE PHASE INVERTER: Solis-40K,Solis-50K,Solis-60K-4G,
Applicable Standard	EN50438 : 2013 for Netherland	

### Test result

#### Test details

Name and address of test house	Ginlong technical Research and develop laboratory
Telephone number	(+86) 574 6578 1607
Date of test	2018.03.15

#### Under/Over Frequency tests

Parameter	Under frequency		Over frequency	
	Frequency	Time	Frequency	Time
Protection limit	47.5 Hz	0.2 s	51.5 Hz	0.2 s
Actual setting	47.5 Hz	0.1 s	51.5 Hz	0.1 s
Trip value (test result)	47.5 Hz	0.1 s	51.5 Hz	0.11 s

#### Under-/Overvoltage tests (single-stage protection)

Parameter	Under voltage		Over voltage	
	Voltage	Time	Voltage	Time
Protection limit	384 V	0.2 s	573 V	0.2 s
Actual setting	384 V	0.1 s	573 V	0.1 s

Trip value (test result)	384 V	0.11 s	574 V	0.12 s
--------------------------	-------	--------	-------	--------

**LoM test**

ROCOF (df/dt)	Neg. gradient		Pos. gradient	
Parameter	Min.	Time	Max	Time
Protection limit	-0.4 Hz/s	0.5 s	+0.4 Hz/s	0.5 s
Actual setting	-0.4 Hz/s	0.4 s	+0.4 Hz/s	0.4 s
Trip value (test result)	-0.4 Hz/s	0.38 s	+0.4 Hz/s	0.41 s

The product stated above have been achieved and processed to the fullness examination according to EN50438 : 2013 for Netherland.

Manufacture Stamp

宁波锦浪新能源科技有限公司  
NINGBO GINLONG TECHNOLOGIES CO., LTD.

Date and place of issue

Ningbo  
2014-5-28

*Zhangkun*

Zhangkun

Information:

All modification to should be confirmed by Ginlong, otherwise this declaration will no longer valid.